IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roger Chamblin DATE 21 Oct 16 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 & Huntsville Rd on NC 2105 Lt 1 mi/f road on Rt on NC 2105 Lt 1st pond Rt on left W 211 - Lt .9 mile S. R. No. _____

SUBDIVISION NAME Hunter Hill LOT NO. _____ SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (X)	
Auto. Dishwasher	Yes ( )	No (X)	
Auto. Wash. Machine	Yes (X)	No ( )	
Site Suitable	Yes (X)	No ( )	

Lot Area 2 acres


Character & Porosity of Soil Cecil Clay

Percolation Rate 40 MPI

Topography 2-6% Slope

Depth to Water Table 60"

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (X)
Public ( )

Installed by J W Jones

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Theard DATE 21 Oct 16

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold